





4816 Upshur Street  
 Bladensburg, MD 20710  
 Phone: 301-403-0045  
 Fax: 301-403-0065

# GENERATOR LOAD TEST REPORT

JOB NAME <b>Democracy III</b>		DATE <b>1/29/13</b>	
CUSTOMER <b>Casidy Turley</b>		JOB / TICKET# <b>804</b>	
ADDRESS <b>6905 Rockledge DR</b>		TECH <b>Steve</b>	
<b>Bethesda, MD</b>		<b>Bryan King</b>	
GENERATOR <b>MTU</b>	ENGINE <b>DETROIT DIESEL</b>	GENERATOR LOCATION <b>Generator room</b>	
MODEL <b>450RXC6DT3</b>	MODEL <b>Series 60 14.7ltr</b>	AMB TEMP <b>50</b>	
SERIAL <b>317922-1-1-0210</b>	SERIAL <b>06A01036191</b>	TOTAL CABLE USED <b>800ft</b>	
SPEC <b>6063HV35</b>	SPEC	KVA 80% <b>540</b>	
OIL FILTERS <b>LF3620</b>	FUEL FILTERS <b>FF86118-86120</b>	AIR FILTERS <b>VF160AE</b>	FUEL
KW <b>450</b>	% LOAD <b>540amps</b>	VOLTS <b>480</b>	PHASE <b>3</b>
		RPM <b>1800</b>	P.F. <b>.8</b>

TIME	HERTZ	AMPS			VOLTS			OIL PRESSURE	WATER TEMP	HOUR METER
		A	B	C	A	B	C			
10:00	60.1	140	138	138	482	476	480	53	190	86
10:15	60.1	282	278	278	482	476	480	51	187	86
10:30	60.1	404	402	402	482	476	482	50	190	86
10:45	60.1	534	532	534	482	476	482	50	190	86
11:00	60.1	534	532	532	482	476	482	49	194	87
11:15	60.1	540	538	538	482	476	482	49	194	87
11:30	60.1	540	538	538	482	476	482	49	194	87
11:45	60.1	540	538	538	482	476	482	49	194	87
12:00	60.1	540	538	538	482	476	482	49	194	88

COMMENTS: No problems All checks ok

READINGS CERTIFIED BY:  PRINTED NAME: Steve Long DATE: 01/29/13  
 CUSTOMER SIGNATURE:  PRINTED NAME: Isac Diaz DATE: 01/30/13